

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Combined inverter/charger and dual independent MPPT solar charger

Name and address of the applicant

Victron Energy B. V.
De Paal 35, 1351 JG Almere
Netherlands

Name and address of the manufacturer

Victron Energy B. V.
De Paal 35, 1351 JG Almere
Netherlands

Name and address of the factory

Note: When more than one factory, please report on page 2☐ Additional information on page 2

Ratings and principal characteristics

DC IN: 48 Vdc, 110 Adc
DC OUT: 48 Vdc, 100 Adc
MPPT IN: 2x 450 Vdc, 13 Adc, 16 Adc Isc
ACIN: 230 Vac, 22 Aac, 50 Hz, 5 kVA / 5 kW
ACOUT: 230 Vac, 22 Aac, 50 Hz, 6 kVA / 5 kW, PF +/-0,8

Trademark / Brand (if any)

Victron Energy

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Multi RS Solar 48/6000/100-450/100

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62109-1:2010, IEC 62109-2:2011

As shown in the Test Report Ref. No. which forms part of this Certificate

22PP580-01_
22PP580-02_1

1

This CB Test Certificate is issued by the National Certification Body

Kiwa Nederland B.V.
Wilmsdorp 50
NL - 7327 AC Apeldoorn
Netherlands

Raphael Rader
- Digitally signed | see <http://ica.kiwa-deutschland.de> for more details -

kiwa

Date: 2025-08-21

Signature: Raphael Rader